



Town of Merrimack, New Hampshire

6 Baboosic Lake Rd · Merrimack, NH 03054 · www.merrimacknh.gov

October 22, 2015

ADDENDUM TO REQUEST FOR PROPOSAL Siding and Windows at Ambulance Garage

In reference to the Town of Merrimack's Request for Proposal for the siding and window project at the Ambulance Garage, due Thursday, October 29, 2015, ***please be advised that the following changes were made during the walk-through:***

- The fees to use the Transfer Station will be waived provided the winning vendor ships in their own truck or trailer, not a dumpster.
- The electric lines shall be wrapped prior to project start date.
- The five (5) large windows shall be replaced.
- The two (2) small windows shall be boarded.
- The air conditioning unit shall be boarded.
- The replacement foam to be installed beneath the siding shall be 1" foam.
- The winning vendor shall use snow white CertainTeed Mainstreet double 4" woodgrain clapboard siding or equivalent.
- The winning vendor shall install new forest green shutters.
- The winning vendor shall install J-Block:
 - Around the electric panel
 - Around the two (2) vents
 - Around the gas line going into the building
 - Around the telephone line going into the building
- The following will be optional items that the Town may or may not add to the scope of work (please enter as a separate item on the bid form):
 - Continuous/ seamless style siding
 - Rain diverters on the roof over the front entrance and garage doors.

Attached is the revised bid form.

Please contact me at xsimpson@merrimacknh.gov or (603) 424-7075 if you have any questions pertaining to this addendum or other portions of our bid request.



TOWN OF MERRIMACK, NEW HAMPSHIRE

FINANCE DEPARTMENT
6 Baboosic Lake Road
Merrimack, NH 03054

Tel: 603-424-7075
Fax: 603-424-0516

Proposal for Windows and Siding for Ambulance Garage

REVISED BID FORM

Deliver bids by 2:00PM on Thursday, October 29, 2015

Replace five windows, according to the Town's bid specifications \$_____

Mfg & Model: _____

Siding, according to the Town's bid specifications \$_____

Mfg & Model: _____

Optional: Continuous/Seamless siding: \$_____

Mfg & Model: _____

Optional: rain diverters: \$_____

The above bid is provided in accordance with the Town's bid invitation dated October 7, 2015, walkthrough on October 21, 2015 and addendum dated October 22, 2015 except as indicated below.

Bidder: _____

Street Address: _____

City, State, Zip Code: _____

Phone No: _____ Fax No: _____

Authorized Signature: _____

Printed Name: _____

Date: _____

E-Mail: _____